

NOTE: IF MUD IS FOUND USE 6" THICK OF NO 57 ROCK AS BEDDING.

**VARIES** 

18"

MIN.

VARIES

WHERE UNSTABLE SOILS ARE ENCOUNTERED, INCLUDING PEAT, MUCK OR OTHER ORGANIC SOILS, ELASTIC SILT OR CLAYS BELOW THE WATER TABLE, A FOUNDATION IS REQUIRED. FOUNDATION MATERIAL SHALL BE 6" COURSE SAND

CLEAN COURSE SAND HYDRAULICALLY -

COMPACTED TO 90% DENSITY MODIFIED PROCTOR T180 OR FLOWABLE FILL AS

APPROVED BY CITY ENGINEER.

<u>utility trench restoration</u>

F:\WORK\\$ALL\CAD-DWG\STANDARDS\CMB STANDARD DETAILS\Public Works Manual\CMB Site Earthwork Details



APPROVED

TITLE: SITE EARTHWORK DETAILS NO.1 UTILITY TRENCH RESTORATION (WITH FLOWABLE FILL OPTION)

SES1